

MDC

Today's Date: 03/25/2021 11:44

Maintenance Workorder Form

Location: Building:
 Section:
 Block:
 Cell:

From: 03/24/2021 to 03/25/2021
 Request Type: All
 Assigned: Larry Coulson

Work Order ID: 3164

Priority: 839-8754

Date Created: 03/25/2021

Status: Open

Created By: HODNETT, LISA

Location: E Unit

Assigned To: Larry Coulson

Request Type: Other

Building:

Block: E1

Section: E Unit

Cell: 01

Request Details

Please test call buttons in several areas to confirm that call buttons do alert master control. Thank you

Repair Details

Various intercoms have been tested. A list of tested intercoms follows: Echo 1 cell 26, Echo 4 cell 16, Fox 5 cell 19, Fox 8 cell 12, Pac 2 cell 2, Pac 2 cell 3. RHU cell intercoms do not forward to Master Control. RHU housing unit will be programmed to forward calls to Master Control when panel is disabled in pod. Echo, Fox & Pac units do forward to Master Control.

Total Work Orders: 1

Total Open Orders: 1

Total Closed Orders: 0

EXHIBIT 8